



1. 1" SERVICE FOR: 5/8" X 3/4", 3/4" AND 1" METERS 2" SERVICE FOR: 1-1/2" AND 2" METERS.
2. PREFERRED LOCATION OF METERS TO BE SET IN GRASS PARKWAY OR AT BACK OF UTILITY EASEMENTS. SEE DOMESTIC SERVICE LOCATION DETAIL.
3. METER BOX & LID SUPPLIED & INSTALLED BY CONTRACTOR. SIZE TO BE COMPATIBLE WITH SERVICE SIZE.
4. POLYETHELENE TUBING ONLY APPROVED IN ADVANCE FOR SPECIAL PROJECTS.
5. ADD 3/4" WASHED ROCK 6" THICK TO BOTTOM OF METER BOX.
6. ENGINEER OF RECORD MUST SUPPLY FLOW CALCULATION TO ESTABLISH ACCEPTABLE WATER VOLUME AND PRESSURE FROM THE WATER MAIN TO THE HOUSE OR BUSINESS. SUCH CALCULATIONS SHALL BE SIGNED AND SEALED BY A FLORIDA LICENSED ENGINEER.

REVISED: SEPT-2009	WATER SERVICES - 1" & 2" SERVICE INSTALLATION	STANDARD DETAIL
ISSUED: SEPT - 2009	CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.	WS-1